## SS 13.3 - SMOKE CURTAINS

System description: Smoke control systems				
	Make	odel Location		
1				
2				
3				
4				
Installation Standard:		<ul> <li>NZS 1668.1:2015 The use of ventilation and air conditioning in buildings Part 1: Fire &amp; smoke control in buildings</li> <li>BS EN 12101.2:2017 Smoke &amp; heat control systems. Natural and heat exhaust ventilators</li> </ul>		
		<ul> <li>BS EN 15269.11:2018 Extended application of test results for fire resistance and/or smoke control for door, shutter &amp; openable window assemblies, including their elements of building hardware. Fire resistance for operable fabrics</li> <li>Specifically Designed Alternative Solution (please specify)</li> </ul>		
Inspections and Maintenance Standard:		<ul> <li>AS 1851:2012 Routine service of fire protection systems and equipment</li> <li>AS 1851:2012 Maintenance of fire protection systems and</li> </ul>		
		<ul> <li>equipment</li> <li>Specifically Designed Alternative Solution (please specify)</li> <li>As per the Compliance Schedule handbook (see below)</li> </ul>		
As a minimum these inspections and maintenance procedures will be carried out:		Planned preventative maintenance and responsive maintenance shall be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required. See below.		
Fr	equency:	Six -monthly	IQP	
		Annual	IQP	
R	<ul> <li>The owner must keep records of all inspections, maintenance repairs undertaken in the previous 24 months. The records must kept with the compliance schedule and as a minimum, include:</li> <li>Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults for remedies applied, and the person who performed the work of A Form 12A provided by an IQP annually.</li> </ul>		inspections, maintenance and 4 months. The records must be and as a minimum, include: ts or preventative maintenance york undertaken, faults found, son who performed the work.	