

## SS 14.1 - EMERGENCY POWER SYSTEMS (Generator)

<b>System description:</b> Emergency power systems – generators only			
	<b>Make</b> (Includes systems for which power relates to e.g. SS1, SS8.)	<b>Model</b>	<b>Location</b>
1			
2			
3			
4			
<b>Performance/Installation Standard:</b>		<input type="checkbox"/> NZS 6104:1981 Specification for emergency electricity supply in buildings	
<b>Inspections and Maintenance Standard:</b>		<input type="checkbox"/> NZS 6104:1981 Specification for emergency electricity supply in buildings <input checked="" type="checkbox"/> As per the Compliance Schedule handbook (see below)	
<b>As a minimum these inspections and maintenance procedures will be carried out:</b>		Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required. See Below	
<b>Inspection frequency and responsibility:</b>		<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner/Agent
		<input checked="" type="checkbox"/> Annual	<input type="checkbox"/> IQP
<b>Reporting:</b>		<input checked="" type="checkbox"/> IQP	
		<p>The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include:</p> <ul style="list-style-type: none"> <li>• Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work.</li> <li>• A Form 12A provided by an IQP annually.</li> <li>• The IQP is responsible for ensuring proper training is delivered and only people who have received training are to perform owner inspections.</li> </ul>	