

# SS 15.1 - SYSTEMS FOR COMMUNICATING EVACUATION

<b>System description:</b> System for communicating spoken information intended to facilitate evacuation.			
	<b>Make</b>	<b>Model</b>	<b>Location</b>
1			
2			
3			
<b>Performance/Installation Standard:</b>	<input type="checkbox"/> NZS 4512: 2010 Fire detection & alarm systems in buildings <input type="checkbox"/> AS 1670.4:2018 Fire detection, warning, control & intercom systems – System design, installation & commissioning, Emergency warning & intercom systems <input type="checkbox"/> AS 2220.1:1989 Emergency warning and intercommunication systems in buildings, Equipment design & manufacture <input type="checkbox"/> Specifically Designed Alternative Solution (please specify)		
<b>Inspections &amp; Maintenance Standard:</b>	<input type="checkbox"/> NZS 4512: 2010 Fire detection & alarm systems in buildings <input type="checkbox"/> AS 2220.1:1989 Emergency warning and intercommunication systems in buildings, Equipment design & manufacture <input type="checkbox"/> AS 1851:2012 Routine service of fire protection systems & equipment <input type="checkbox"/> Specifically Designed Alternative Solution (please specify) <input checked="" type="checkbox"/> As per the Compliance Schedule handbook (see below)		
<b>As a minimum these inspections and maintenance procedures will be carried out:</b>	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required. See Below		
<b>Inspection frequency and responsibility:</b>	<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner	
	<input checked="" type="checkbox"/> Annual	<input checked="" type="checkbox"/> IQP	
<b>Reporting:</b>	The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: <ul style="list-style-type: none"> <li>• Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work.</li> <li>• A Form 12A provided by an IQP annually.</li> </ul>		