

SS 2 - EMERGENCY WARNING SYSTEMS

System description: Automatic or Manual Emergency Warning System for Fire or other dangers	
Make, Model & Type:	This is a Type X Alarm
Location:	
Warning Devices:	<input type="checkbox"/> Manual (Call Points) <input type="checkbox"/> Heat Detectors <input type="checkbox"/> Smoke Detectors <input type="checkbox"/> Strobe Lighting <input type="checkbox"/> Alarm is Brigade Connected
Alarm Interfacing: E.G. SS9, SS3/3	
Performance/Installation Standard:	<input type="checkbox"/> NZS 4512: 2010 Fire Detection and alarm systems in buildings. <input type="checkbox"/> NZS 4561: 1973 Specification for manual fire alarm systems for use in buildings. <input type="checkbox"/> AS/NZS 1851: 2012 Routine service of fire protection systems & equipment. <input type="checkbox"/> Specifically Designed Alternative Solution (please specify)
Inspections & Maintenance Standard and Requirements:	<input type="checkbox"/> NZS 4512: 2010 Fire Detection and alarm systems in buildings. <input type="checkbox"/> NZS 4561: 1973 Specification for manual fire alarm systems for use in buildings. <input type="checkbox"/> AS/NZS 1851: 2012 Routine service of fire protection systems & equipment. <input type="checkbox"/> Specifically Designed Alternative Solution (please specify) <input checked="" type="checkbox"/> As per the Compliance Schedule handbook (see below)
As a minimum these inspections and maintenance procedures will be carried out:	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.
Inspection frequency and responsibility:	<input type="checkbox"/> Weekly by the Owner <input type="checkbox"/> Monthly by the Owner <input type="checkbox"/> Monthly by the IQP <input type="checkbox"/> 3 Monthly by the Owner <input type="checkbox"/> 3 Monthly by the IQP <input checked="" type="checkbox"/> Annually by the IQP

SS 2 - EMERGENCY WARNING SYSTEMS

Reporting:	<p>The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include:</p> <ul style="list-style-type: none">• Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work.• Register of training for owner inspections.• A Form 12A provided by an IQP annually• The IQP is responsible for ensuring proper training is delivered and only people who have received training are to perform owner inspections.
-------------------	--