

## SS 3.3 - INTERFACED FIRE OR SMOKE DOORS OR WINDOWS

<b>System description:</b> Interfaced fire or smoke doors or windows			
No.	Make	Model	Location
1			
2			
3			
4			
5			
6			
<b>Performance/Installation Standard:</b>		<input type="checkbox"/> NZS 4239:1993 Automatic sliding door assemblies <input type="checkbox"/> AS/NZS 1905.1: 1997 Components for the protection of opening in fire-resistant walls <input type="checkbox"/> NZS 4520 :2010 Fire-resistant door sets <input type="checkbox"/> AS 4178:1994 Electromagnetic door holders <input type="checkbox"/> Specifically Designed Solution (please specify) <input checked="" type="checkbox"/> C/AS2: 3.15.9 (a)(b)(c) & 3.15.10 (a)(b)(c)	
<b>Inspections &amp; Maintenance Standard and Requirements:</b>		<input type="checkbox"/> NZS 4239:1993 Automatic sliding door assemblies <input type="checkbox"/> NZS 4520 :2010 Fire-resistant door sets <input type="checkbox"/> AS 4178:1994 Electromagnetic door holders <input type="checkbox"/> Specifically Designed Solution (please specify) <input checked="" type="checkbox"/> As per the Compliance Schedule handbook (see below)	
<b>As a minimum these inspections and maintenance procedures will be carried out:</b>		Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.	
<b>Inspection frequency and responsibility:</b>		<input checked="" type="checkbox"/> Daily (General Observation)	<input checked="" type="checkbox"/> Owner
		<input checked="" type="checkbox"/> Monthly (Inspection)	<input checked="" type="checkbox"/> Owner or IQP
		<input checked="" type="checkbox"/> Annually	<input checked="" type="checkbox"/> IQP
<i>Monthly Inspections (Daily if applicable)</i>		<ul style="list-style-type: none"> <li>• Doors should be inspected to ensure they can be opened and that they are not:               <ul style="list-style-type: none"> <li>• locked</li> <li>• barred</li> <li>• blocked</li> </ul> </li> </ul>	
<b>Reporting:</b>		The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include:	

## SS 3.3 - INTERFACED FIRE OR SMOKE DOORS OR WINDOWS

	<ul style="list-style-type: none"><li>• Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work.</li><li>• A Form 12A provided by an IQP annually.</li><li>• The IQP is responsible for ensuring proper training is delivered and only people who have received training are to perform owner inspections.</li></ul>
--	---