

SS 4 - EMERGENCY LIGHTING SYSTEMS

(Photo-Luminescent Systems)

System description: EMERGENCY LIGHTING SYSTEMS – PHOTO LUMINESCENT SIGNS & MARKINGS			
No.	Make	Model	Location
1	ECOGLO EXIT SIGNS	PHOTO LUMINESCENT <i>delete if not applicable)</i>	AS PER THE ATTACHED PLAN
2	ECOGLO PATH MARKER	PHOTO LUMINESCENT TAPE <i>(delete if not applicable)</i>	AS PER THE ATTACHED PLAN
3	ECOGLO STAIR NOSING'S	PHOTO LUMINESCENT TAPE <i>(delete if not applicable)</i>	AS PER THE ATTACHED PLAN
Performance/Installation Standard:		✓ Specifically Designed Alternative Solution	
Inspections and Maintenance Standard:		✓ Specifically Designed Alternative Solution	
As a minimum these inspections and maintenance procedures will be carried out:		<p>Six monthly checks – Owner or appointed agent: Check that all installed photo-luminescent products are not damaged and are clean from dust build up, not obscured, in working order and in their original locations.</p> <p>Annual check – IQP: Check that all installed photo-luminescent products are not damaged and are clean from dust build up, not obscured, in working order and in their original locations A record of the six monthly checks having been undertaken should also be available. See below.</p>	
Inspection frequency and responsibility:		✓ Six-monthly	✓ Owner
		✓ Annually	✓ IQP
Reporting:		<p>The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include:</p> <ul style="list-style-type: none"> • Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. • A Form 12A provided by an IQP annually. • The IQP is responsible for ensuring proper training is delivered and only people who have received training are to perform owner inspections. 	