SS 5 - ESCAPE ROUTE PRESSURISATION SYSTEMS

System description: Escape route pressurisation systems			
No.	Make(major components)	Model	Location
1			
2			
3			
4			
Performance/Installation Standard:		 NZS 1668.1:2015 The use of air conditioning in buildings − Fire & smoke control in buildings AS 1851:2012 Routine service of fire protection systems & equipment Specifically Designed Alternate Solution (please specify) Other (Historical) 	
Inspections and Maintenance Standard:		□ AS 1851 □ Specifically Designed Alternate Solution (please specify) □ Other (Historical) ✓ As per the Compliance Schedule handbook (see below)	
Inspection frequency and		☐ Monthly	□ IQP
responsibility:	☐ Six-monthly	□ IQP	
		✓ Annually	✓ IQP
Inspections and Maintenance: Planned preventative maintenance and results should be carried out in accordance performance and inspection standard or do system will operate as required.		accordance with the nominated standard or document to ensure the	
Reporting:		 The owner must keep records of all inspection, maintenance and repairs undertaken in the previous 24 months. The records must be kept on site and as a minimum, include: details of any inspections, tests or preventative maintenance carried out, including dates, work undertaken, faults found, remedies applied, and the person who performed the work details of any other faults found or maintenance and repair work undertaken to maintain the system in working order, including dates, work undertaken, faults found, remedies applied and the person who performed the work A Form 12A provided by an IQP annually. 	