SS 6 - RISER MAINS SYSTEMS

System description: Riser Mains						
	Make	Model	Location		Dry tick	Wet
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Installation Standard:		 NZS 4510: 2008 Fire Hydrant systems for buildings Specifically Designed Alternative Solution (please specify) Other (Historical)				
Inspections and Maintenance Standard:		 NZS 4510: 2008 Fire Hydrant systems for buildings Specifically Designed Alternative Solution (please specify) As per the Compliance Schedule handbook (see below) 				
As a minimum these inspections and maintenance procedures will be carried out:		Planned preventative maintenance and responsive maintenance should be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.				
Inspection frequency and responsibility:		Monthly		IQP		
	•	 Annually 		V IQP		
rep	 As a minimum these reporting procedure will be carried out: The owner must keep records of all inspections, maintenance an repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found remedies applied, and the person who performed the work. A Form 12A provided by an IQP annually. 					