

SS 8.2 – PLATFORM, LOW-SPEED & SERVICE LIFTS

System description: Platform, low-speed & service lifts			
	Make	Model	Location
1			
2			
3			
4			
Performance/Installation Standard		<input type="checkbox"/> Rules for Power Lifts Not Exceeding 750 Watts (1 H.P.) (Historical) <input type="checkbox"/> Specifically Designed Alternative Solution (please specify)	
Inspections & Maintenance Standard and Requirements:		<input type="checkbox"/> Compliance Schedule Handbook – NZS 4334 or D2/AS2 <input type="checkbox"/> Rules for Power Lifts Not Exceeding 750 Watts (1 H.P.) <input type="checkbox"/> Specifically Designed Alternative Solution (please specify) <input checked="" type="checkbox"/> As per the Compliance Schedule handbook (see below)	
As a minimum these inspections and maintenance procedures will be carried out:		Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required. See below.	
Inspection frequency and responsibility:		<input checked="" type="checkbox"/> Annually	<input checked="" type="checkbox"/> IQP
Reporting:		The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: <ul style="list-style-type: none"> • Details of any inspections, tests or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. • A Form 12A provided by an IQP annually. 	